

# KEMA Test Certificate

No. 2119423.104

Issued to: Terasaki Electric Co. Ltd.  
7-2-10 Hannan-cho Abeno-ku  
545-0021 Osaka  
Japan

For the product: Moulded case circuit-breakers

Trade name: TERASAKI

Type/Model: S160 - SCF; S160 - SCJ

Ratings: 1P, 2P, 3P, 3P+N, 4P; Ue = 240/415 Vac;  
In = from 15 to 160 A;  
Icu = 25 kA; Ics = 13 kA;

Subject: Type tests

Requirements: IEC 60947-2 (Fourth edition)  
IEC 60947-1 (Fifth edition)

Remarks: -

This Test Certificate is granted on account of an examination by KEMA, the results of which are laid down in test reports nos. 2119510.60 to 2119510.69, dated October 26, 2009.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Test Certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality B.V.  
Arnhem, October 26, 2009



H.L. Schendstok  
Certification Manager

©Publication of this document is allowed. Publication in total or in part and/or reproduction in whatever way of the contents of the above mentioned report(s) is not allowed unless permission has been explicitly given either in the report(s) or by previous letter.

KEMA Quality B.V. Utrechtseweg 310, 6812 AR Arnhem P.O. Box 5185, 6802 ED Arnhem The Netherlands  
T +31 26 3 56 20 00 F +31 26 3 52 58 00 [contact@kema.com](mailto:contact@kema.com) [www.kema.com](http://www.kema.com) Registered Arnhem 09085396

Experience you can trust.