

# KEMA Test Certificate

No. 2119511.04KTC

Issued to: Terasaki Electric Co. Ltd.  
7-2-10 Hannan-cho Abeno-ku  
545-0021 Osaka  
Japan

For the product: Moulded case circuit-breakers

Trade name: TERASAKI

Type/Model: E250 - SCJ; E250 - SCF

Ratings: 3P, 4P; Ue = 415 Vac;  
In = from 100 to 250 A;  
Icu = 16 kA; Ics = 8 kA;

Subject: Type tests


Requirements: IEC 60947-2 (Fourth edition)  
IEC 60947-1 (Fifth edition)

Remarks: -

This Test Certificate is granted on account of an examination by KEMA, the results of which are laid down in a test report no. 2119511.60 to 2119511.65, dated November 6, 2009.

The examination has been carried out on one single specimen of the product, submitted by the manufacturer. The Test Certificate does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by KEMA is not the responsibility of KEMA.

KEMA Quality B.V.  
Arnhem, November 6, 2009



H.L. Schendstok  
Certification Manager